

Disaster Recovery Project Sheet

Type of Business

Paper Manufacturing

Incident Description

Switch Room Fire / heavy soot contamination and fire fighting water damage to electrical switch gear.

Damaged / Contaminated Equipment

- Electrical cabinets
- Switch gear
- Cable ducts
- Entire room surfaces

Description of Recovery

- Report to Loss Adjuster
- Decontamination of equipment using Dry Ice Blasting and detail chemical cleaning
- Decontamination of floor recessed cable ducts and room surfaces using Dry Ice Blasting and detail chemical cleaning

Equipment Replacement Value

unknown

Total Recovery Cost

\$ 30,000

Recovery time to restart of business

1 day

Total Recovery Time

2 weeks

Paper Manufacturing



Contamination on top of electrical cupboards before cleaning



Switch Room fully decontaminated



Electrical cupboard opened during cleaning process



Dry Ice Blast Cleaning of floor recessed cable trenches